

Office of the Executive Engineer,
Elect, Dept., Div-VII (O & M)
Curchorem-Goa 403 706

“BY REGISTERED POST WITH A.D.”

No.EE/Div-VII/Tech-2/Quot-04[17-18]/ 563 /2017-18

Date: - 03/05/2017.

On Behalf of The Governor of Goa, quotation for supply of below mentioned materials as per the terms and conditions depicted in Annexure- I & II is invited.

Sub: - Quotation for supply of Tinned Copper Fuse Wire & Kit Kat Fuses of various ratings.

| S. No | Description of Materials | Qty | Rate | Amt. |
|---|--|----------|------|------|
| 1 | Tin coated copper Fuse Wire conforming to IS 9926/1981 amended upto date of following sizes. | | | |
| | a) 200A | 20 Kgs | | |
| | b) 150A | 20 Kgs | | |
| | c) 100A | 30 Kgs | | |
| | d) 80A | 30 Kgs | | |
| | e) 60A | 20 Kgs | | |
| | f) 30 A | 20 Kgs | | |
| 2. | L.T. rewirable fuse unit complete with ceramic base and carrier of rated voltage 415V AC, Rated breaking capacity 4KA conforming to IS: 2086-1982 as amended upto date and of the following rated operational current. The fuse carrier shall bear marking as per I.S. Extended type of terminals with nuts and bolts shall be provided with fuse base for 63A and above rating for fixing of the cable lugs. The fuse carrier contacts and the extension strips shall be made up of electro plated, electrolytic copper. All other current carrying parts of fuse unit shall be made of electroplated brass / copper. Adequate size terminal holes in the fuse carrier along with terminal screws shall be provided to fix fuse wire. Acceptance and routine tests as per IS shall be carried out at the manufacturers works and test reports shall be furnished before supply of material. The Department reserves the right to witness above tests. | | | |
| | 1) 100 A | 120 nos. | | |
| | 2) 200 A | 120 nos. | | |
| Total Amount in Rs | | | | |
| E.M.D: 7,456/- (Rupees Seven Thousand Four Hundred Fifty Six only) | | | | |
| Last date & time of receipt of quotation: 19/05/2017 upto 10.00hrs. | | | | |
| Date & time of opening of quotation: 19/05/2017 at 10.30hrs. | | | | |
| Time Allowed For Completion of supply: 15 days. | | | | |
| All other terms, conditions/Rules & Regulations in force shall be applicable. | | | | |
| Approved Makes for Kit Kat Fuses: HPL,GEO, Universal cable, KEI, Finolex | | | | |

Encl: - As above.

Name:

Address:

Signature of Contractor:



EXECUTIVE ENGINEER-VII

To,

Copy to:-

1) The Superintending Engineer, Elect. Dept, Circle-I/II, Margao/Panaji.... For information.

2) The Executive Engineer, Elect. Dept, Div. No. I/II/III/IV/V/VI/VIII/IX/X/XI/XII/XIII/XIV/XV/XVI/XVII/XVIII Panaji/ Margao/ Ponda/ Bicholim/ Mapusa/ Tivim/ Vasco/ Xeldem/ Corlim/ Verna/ Patto Plaza Panaji.....For information.

3) The Divisional Accountant, Accounts Section, Div-VII, Curchorem....He is requested to be Present on the day of opening.

4) The Sub-Divisional Engineer, Elect. Sub-Div- I/ II/ III/ IV Curchorem/ Quepem/ Sanguem.

5) The Director of Information & Technology, Department of Information Technology, IT HUB, 2nd floor, Altinho, Panaji-GoaWith a request to publish the quotation called by this office for supply of Tinned Copper Fuse Wire & Kit Kat Fuses of various ratings on Goa Govt. State portal by 03/05/2017. (E-mail sent to stateportal.goa@nic.in).