



Government of Goa
DEPARTMENT OF HOME (GENERAL)
SECRETARIAT
Porvorim – Goa
Pin- 403521

No:3/5/97-IID(G) Part

1485

Date:- 17/05/2018

NOTIFICATION

In exercise of the powers conferred by sub-section (1) of section 13 of the Goa , Daman and Diu Fire Force Act,1986 (Act No. 9 of 1986), read with section 21 of the General Clauses Act, 1897 (10 of 1897), the Government of Goa hereby amends the Government Notification No. 3/5/97-IID(G) Part /3934 dated 17/12/2014, published in the Official Gazette, Series I No. 39, dated 26/12/2014 (hereinafter referred to as the "principal Notification"), as follows:-

In the principal Notification,-

- (i) for the words "specified in Annexure II hereto", the words "specified in Annexure II hereto and the premises as specified in Annexure III hereto shall take such precautions as specified therein" shall be substituted;
- (ii) In Annexure I , in clause (xi), the expression "other than the shop as defined under the Goa, Daman and Diu Shops and Establishments Act, 1973 (13 of 1974) falling within the jurisdiction of Village Panchayats" shall be omitted;
- (iii) After Annexure II, the following Annexure shall be inserted, namely,-

"Annexure III

1. The Shops and Establishment/Guest Houses/Temporary Structures/ Beach Shacks upto 50m² shall provide one portable Fire Extinguisher of ABC Dry Powder (Stored Pressure Type) of 4 kg /6 kg capacity or one 4.5 kg capacity Carbon di-oxide Fire Extinguisher conforming to Bureau of Indian Standard -2190.
2. The Shops and Establishment/Guest Houses/Temporary Structures/Beach Shacks above 50m² and upto 100 m² shall provide two Portable Fire Extinguisher of ABC Dry Powder (Stored Pressure Type) of 4 kg/6 kg capacity or two 4.5 kg capacity Carbon di-oxide Extinguisher conforming to Bureau of Indian Standard-2190.

- 79/c
3. The Shops and Establishment/Guest Houses/Temporary Structures/Beach Shacks which use LPG commercial cylinder upto 50 kg in an area of 50m² shall have an additional portable Fire Extinguisher of ABC Dry Powder (Stored Pressure Type) of 4 kg/ 6 kg capacity or one 4.5 kg capacity Carbon di-oxide Extinguisher conforming to Bureau of Indian Standard-2190.
 4. The Shops and Establishment which use LPG commercial Cylinder beyond 50 kg shall be as per Bureau of Indian Standard-6044 (Part 1) for Storage and Use of LPG cylinder . In such cases, prior No Objection Certificate from the department shall be mandatory.
 5. The Fire Safety required for category (1), (2) and (3) above shall be abided by the respective owner /occupant and a "Self Declaration" to that effect as below, on Rs. 100 Non-Judicial Stamp Paper, shall accompany his application to the respective Licensing Authority.

SELF DECLARATION.

I Shri/Smt.....S/o / D/o /w/o of Shri /Smt. Owner /Occupier of Shop Nolocated inhereby declare that my Commercial establishment is having an area ofm² and have accordingly installed One /Two Portable Fire Extinguisher in my premises.

I have made myself familiar with the safe use of the Portable Fire Extinguisher.

Place :-

(Signature)

Dated:-

Name & Addresses.".

This Notification shall come into force with effect from 01/06/2018.

By order and in the name of
the Governor of Goa,

Nectal Amonkar

(Nectal Amonkar)
Under Secretary (Home)

To,

The Director, Printing & Stationery, Government Printing Press, Panaji, with a request to publish the same in the Govt. Gazette and furnish 5 copies of the same to this Department and 5 copies to the Director, Directorate of Fire & Emergency Services, St. Inez, Panaji.

Copy to :

The Director, Directorate of Fire and Emergency Services, St. Inez, Panaji.