

COMMON SET OF DEVIATIONS

Tender Notice No.: *GSIDC/ ENGG./NIT-103/2019-2020 dated 17th December 2019 - Line A3*

Pre-bid queries last date of submission: *23rd December 2019*

Sr. No.	Volume / Chapter/ Clause / Item No. / Page No.	Clarification / changes sought by Prospective Bidders	Decision of GSIDC
1.	Volume II, Item No. A2, Page 17	The outlets should Quick Connect Type and gas specificity is accomplished by “100% metal outlet”	Strictly as per tender
2.	Volume II, Item No. A5, Page 19	The digital and touch screen panel / LED readout shall provide a constant indication of each service being measured.	Acceptable
3.	Volume II, Item No. A5, Page 19	In the calibration mode the following parameters shall be field adjustable: <ul style="list-style-type: none"> • Imperial /Metric Units - to be deleted 	Strictly as per tender
4.	Volume II, Item No. A5, Page 19	Digital / LED display of line pressure for all the services with factory calibrated pressure sensors	Acceptable
5.	Volume II, Item No. A5, Page 20	Protected programming facility of alarm limits. – To be deleted	Strictly as per tender
6.	Volume II, Item No. A6, Page 20	It should have a digital 3.5” colourful display since 7” is company specific	Strictly as per tender
7.	Volume II, Item No. A7, Page 23	The Contractor should make arrangement of necessary medical gases for testing and commissioning of the manifold and system. - To be deleted	Strictly as per tender

COMMON SET OF DEVIATIONS

Sr. No.	Volume / Chapter/ Clause / Item No. / Page No.	Clarification / changes sought by Prospective Bidders	Decision of GSIDC
8.	Volume II, Item No. A9, Page 25	It should have a digital 3.5” colourful display since 7” is company specific	Strictly as per tender
9.	Volume II, Item No. A10, Page 29	The Contractor should make arrangement of necessary medical gases for testing and commissioning of the manifold and system. - To be deleted	Strictly as per tender
10.	Volume II, Item No. A18, Page 36	All down drops shall be installed at one end preferably & vertical drop installed at one end.	Not acceptable. Strictly as per tender
11.	Volume II, Page 36	<u>Colour Coding:</u> If products and installation is done as per NFPA colour coding is not valid.	Strictly as per tender
12.	Volume II	In specifications, it is mentioned that all products should be as per HTM-01-03 and NFPA 99 C. – To be amended/ deleted.	Strictly as per tender
13.	Volume II, Item Nos. A2 & A3, Page 38	<u>Approved Makes:</u> GCE, MMPL, Arigmed Mexico, Becon Medeas, Ohio Medical, Pneumatech Medical Gas Solutions UK, Silbermann Technologies	Acceptable

COMMON SET OF DEVIATIONS

Sr. No.	Volume / Chapter/ Clause / Item No. / Page No.	Clarification / changes sought by Prospective Bidders	Decision of GSIDC
14.	Volume II, Item Nos. A4 & A5 Page 38	<u>Approved Makes:</u> Arigmed Mexico, Beacon Medaes, Aktiv Technologies,Ohio Medical, Pneumatech Medical Gas Solutions UK, Silbermann Technologies	Acceptable
15.	Volume II, Item Nos. A6 & A9, Page 38	<u>Approved Makes:</u> Arigmed Mexico, Beacon Medaes, Ohio Medical, MMPL, Draeger, Pneumatech Medical Gas Solutions UK, Silbermann Technologies	Acceptable
16.	Volume II, Item Nos. A7, A8, A10, A13, A14, A15, A16, A18 Pages 38 & 39	<u>Approved Makes:</u> Arigmed Mexico, Beacon Medaes, Aktiv Technologies,Ohio Medical, MDD, MPS, NSP Hospitech,Pneumatech Medical Gas Solutions UK, Silbermann Technologies	Acceptable
17.	Volume II, Item Nos. A11 & A12, Page 38	<u>Approved Makes:</u> Anest Iwata, FS Curtis, Ingersoll Rand,Pneumatech Medical Gas Solutions UK,Silbermann Technologies	Acceptable