



Government of Goa  
Office of the Executive Engineer,  
Electricity Department,

Division-VII, Curchorem-Goa Pin Code 403706

E-mail: ee7-elec.goa@nic.in Ph: 0832-2650632, Fax: 0832-2650011

4  
Inward No. 1264907  
Date: 04/06/2020

BY SPEED POST/HAND DELIVERY

No.EE/Div-VII/Tech-2/Quot-13 (20-21) / 55X /2020-21

Dated: - 26 /05/2020

Sub: - Quotation for procurement of 11KV CTs of Ratio 200-100/5-5A & 11KV Outdoor type oil cooled CTPT Unit.

On Behalf of The Governor of Goa, quotation for the below mentioned work as per the terms and conditions depicted in Annexure-I, II & III is invited

QUOTATION

Sr. No	Description	Unit	Qty.	Rate in figures & words (Rs.)	Amount in figures (Rs.)
1.	Supply of 11KV Current transformer, outdoor oil cooled dead tank type, having ratio 200-100/5-5A Burden/Class: Core-I: 30VA/CL 0.5 @200A. Core-II: 30VA/5P10 @200A. STR: 25KA 3sec. l dyn 62.5KA.	Nos.	03		
2.	Supply of 11KV Outdoor type oil cooled combined CTPT unit with system voltage 12KV insulation class A, Qty. of oil 50liters having Single CT Ratio 3x12.5/5 and PT Ratio 3x11KV/110V, having 03nos. Of CTs & 03nos. of PTs. suitable for 3Ph 4Wire metering system.  CT specification: Ratio: 12.5/5A, 1 Core, Burden 15VA, Accuracy class 1, STC/VF 4.5KA for 1 sec.  PT specification: Ratio 11000/110V Burden 100VA Accuracy class 1, STC/VF 1.2 continuous. as per the enclosed specification in the Annexure-III.	No.	01		
	Sub total in Rs.				
	Add GST @ 18%				
	Grand Total in Rs.				
A.M.D. Rs. 3, 149 /- (Rupees Three Thousand One Hundred Forty Nine only)					
Last date & time of receipt of quotation: 04/06/2020 upto 15:00hrs.					
Date & time of opening of quotation: 04/06/2020 at 15.30hrs.					
All other Rules & Regulations in force shall be applicable					
For more details please visit either Goa Govt. State portal or this office on any working day between 14:30 to 17:00hrs					
Reputed approved Makes: Pragati/Goa Electric/Kalpa/Kappa/ Kapco/CGL/Power and Industrial Solutions/Gyro					

Sealed quotation alongwith attached Terms and Conditions duly signed & super scribed on the top of envelop as "Quotation for procurement of 11KV CTs of Ratio 200-100/5-5A & 11KV Outdoor type oil cooled CTPT Unit." should be inserted in the quotation box kept at office of the Executive Engineer, Elect, Dept., Div-VII (O & M) Curchorem or should reach to this office by post/ courier service on or before 04/06/2020 upto 15.00hrs. The quotation will be opened at 15.30hrs. on the same day.

Name:

Signature:

Stamp of the Contractor:

Encl: As above

To,

EXECUTIVE ENGINEER-VII.

P.T.O.

Passal