



Government of Goa
Office of the Executive Engineer,
Electricity Department,
Division-VII, Curchorem-Goa Pin Code 403706



E-mail: ee7-elec.goa@nic.in Ph: 0832-2650632, Fax: 0832-2650011

BY SPEED POST/HAND DELIVERY

No.EE/Div-VII/Tech-2/Quot-23 (21-22)/3320/2021-22

Date: 09/11/2021

Sub: - Quotation for procurement of 33KV CTs of Ratio 25/5A, 11KV Outdoor type oil cooled CTPT Unit and 11KV cast resin insulated Current Transformer of ratio 25/5A.

On Behalf of The Governor of Goa, quotation for the below mentioned work as per the terms and conditions depicted in Annexure-I, II & III is invited

QUOTATION

Sr. No	Description	Unit	Qty.	Rate in figures & words (Rs.)	Amount in figures (Rs.)
1.	Supply of 33KV Current transformer, outdoor oil cooled dead tank type, having ratio 25/5A, BIL: 70KV/170kVp, STC: 13.1KA for 1Sec, 50Hz, HSV: 36KV, Insulation class:A, Core: 1, Class: 0.5s, Burden: 15VA, STD: IS 2705/1992 as per the enclosed specification in the Annexure-III.	Nos.	02		
2.	Supply of 11KV Outdoor type oil cooled combined CTPT unit with system voltage 12KV insulation class A, Qty of oil 50liters having Single CT Ratio 3x50/5 and PT Ratio 3x11KV/110V, having 03nos. Of CTs & 03nos. of PTs. suitable for 3Ph 4Wire metering system. CT specification: Ratio: 50/5A, 1 Core, Burden 15VA, Accuracy class 0.5s, STC/VF 4.5KA for 1 sec. STD: IS:2705/1992 PT specification: Ratio 11000/110V Burden 100VA Accuracy class 0.5s, STC/VF 1.2 continuous. STD: IS:3156/1992 as per the enclosed specification in the Annexure-III.	No.	01		
3.	Supply of 11KV cast resin insulated Current Transformer of ratio 25/5A, Indoor, Single Phase, wound Primary, 0.5s Class or better conforming to IS 2705 Part 1 &2 1992 as amended upto date. as per the enclosed specification in the Annexure-III	Nos.	03		
	Sub total in Rs.				
	Add GST @ 18%				
	Grand Total in Rs.				

E.M.D. Rs. 2, 659 /- (Rupees Two Thousand Six Hundred Fifty Nine only)

Last date & time of receipt of quotation: 16/11/2021 upto 15:00hrs.

Date & time of opening of quotation: 16/11/2021 at 15.30hrs.

All other Rules & Regulations in force shall be applicable

For more details please visit either Goa Govt. State portal or this office on any working day between 14:30 to 17:00hrs

Reputed approved Makes: Pragati/Goa Electric/Kalpa/Kappa/ Kapco/CGL Power and Industrial Solutions/Gyro

Sealed quotation alongwith attached Terms and Conditions duly signed & super scribed on the top of envelop as "Quotation for procurement of 33KV CTs of Ratio 25/5A, 11KV Outdoor type oil cooled CTPT Unit and 11KV cast resin insulated Current Transformer of ratio 25/5A." should be inserted in the quotation box kept at office of the Executive Engineer, Elect, Dept., Div-VII (O & M) Curchorem or should reach to this office by post/ courier service on or before 16/11/2021 upto 15.00hrs. The quotation will be opened at 15.30hrs. on the same day.

Name:

Signature:

Stamp of the Contractor:

Encl: As above

Sd/-

EXECUTIVE ENGINEER-VII.

To,

P.T.O.

Copy to:-

- 1) The Superintending Engineer, Elect. Dept., Circle-I/II, Margao/Panaji.... For information.
- 2) The Executive Engineer, Elect. Dept., Div. Nos: I/II/III/IV/V/VI/VIII/IX/X/XI/XII/XIII/XIV/XV/ XVI/ XVII /XVIII Panaji/Margao/Ponda/Bicholim/Mapusa/Tivim/Vasco/Xeldem/Corlim/Verna/ Patto Plaza Panaji.....For information.
- 3) The Divisional Accountant, Accounts Section, Elect. Div-VII, Curchorem....He is directed to be present on the day of opening.
- 4) The Sub Divisional Engineer, Elect. Sub-Div-III/IV, Sanguem/Curchorem.
- 5) The Director of Information Technology, IT HUB, 2nd Floor, Altinho, Panaji-Goa.... With a request to publish the quotation called by this office on Goa Govt. State portal by 09/11/2021 (E-mail sent to stateportal.goa@nic.in)