

**BY SPEED POST/HAND DELIVERY**

No.EE/Div-VII/Tech-2/Quot-25 (21-22)/3421/2021-22

Dated: 11/11/2021

Sub: - Quotation for supply of 33KV CTs of ratio 200-100/5-5A & 33KV PTs of ratio 33KV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ . for 33/11KV Shigao Substation under Elect. Sub Div-IV, Curchorem & 33/11KV Waddem Substation under Elect Sub Div-III, Sanguem respectively.

On Behalf of The Governor of Goa, quotation for the below mentioned materials as per the terms and conditions depicted in Annexure-I, II & III (A) & (B) is invited.

**QUOTATION**

Sr. No	Description	Unit	Qty.	Rate in figures & words (Rs.)	Amount in figures (Rs.)
1	Supply of 33KV CTs of ratio 200-100/5-5A, Core-I : 15VA, Class-5P, SF-20 Core-II : 15VA, Class-0.5s STC: 25KA/1sec. Th. dy. 62.5KA (P) Type: Outdoor oil cooled live tank type, Current transformer as per the enclosed technical specification in the Annexure-III.	No.	01		
2	Supply of 36KV, 33KV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ , Outdoor oil cooled dead tank type, single-phase single pole insulated, OIP Insulated, Copper wound Potential Transformer Hermetically sealed with Insulator having a total creepage distance of 900mm (Min.) provided with pressure relieving device nitrogen cushioning complete with first filling of oil etc. PT Ratio: 33KV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ , Rated burden: 200VA, Accuracy Class: 0.5s, Frequency: 50Hz, Voltage factor: 1.2continuous & 1.5 for 30seconds, Nominal system voltage: 33KV, Highest system voltage: 36KV, Insulation level: 36/70/170KVp, Insulation Class: A, Insulation level: 70KV/170KV (P), as per the enclosed technical specification in the Annexure-III.	No.	01		
Sub Total in Rs.					
Add GST@18%					
Grand total in Rs					
E.M.D. Rs. 2, 211/- (Rupees Two Thousand Two Hundred Eleven only)					
Last date & time of receipt of quotation: 23/11/2021 upto 15:00hrs.					
Date & time of opening of quotation: 23/11/2021 at 15.30hrs.					
All other Rules & Regulations in force shall be applicable For more details please visit either Goa Govt. State portal or this office on any working day between 14:30 to 17:00hrs					
Reputed Makes: Pragati/Kappa/Kapco/Gyro/CGL Power & Industrial solutions/Kalpa/Goa Electric					

Sealed quotation alongwith attached Terms and Conditions duly signed & super scribed on the top of envelop as "Quotation for supply of 33KV CTs of ratio 200-100/5-5A & 33KV PTs of ratio 33KV/ $\sqrt{3}$ /110V/ $\sqrt{3}$ , for 33/11KV Shigao Substation under Elect. Sub Div-IV, Curchorem & 33/11KV Waddem Substation under Elect Sub Div-III, Sanguem respectively" should be inserted in the quotation box kept at office of the Executive Engineer, Elect, Dept., Div.-VII (O & M) Curchorem before Last date & time of receipt of quotation.

Name:

Signature:

Stamp of the Contractor:

Encl: As above

Sd/-

EXECUTIVE ENGINEER-VII.

To,

\_\_\_\_\_

P.T.O.

Copy to:-

- 1) The Superintending Engineer, Elect. Dept. Circle-I, Margao.... For information.
- 2) The Executive Engineer, Elect.Dept,Div.No.I/II/III/IV/V/VI/VIII /IX/X/XI/XII/XIII /XIV,XV/XVI /XVII/XVIII Panaji/Margao/Ponda/Bicholim/Mapusa/Tivim/Vasco /Xeldem/Corlim/Verna/Patto Plaza Panaji.....For information.
- 3) The Divisional Accountant, Accounts Section, Div-VII, Curchorem....He is requested to be Present on the day of opening.
- 4) The Sub-Divisional Engineer, Elect. Sub-Div-III/IV, Sanguem/Curchorem
- 5) The Director of Information & Technology, IT HUB, 2nd floor, Altinho, Panaji-Goa ....With a request to publish the quotation called by this office for Quotation for supply of 33KV CT of ratio 200-100/5-5A & 33KV PT of ratio 33KV/RT3/110V/RT3 for Elect. Sub Div-IV, Curchorem & Sub Div-III, Sanguem respectively”\_on Goa Govt. State portal by 15/11/2021. (E-mail sent to [stateportal.goa@nic.in](mailto:stateportal.goa@nic.in))