

Inspectorate of Factories & Boilers

Altinho, Panaji, Goa

NOTIFICATION

No.CIF/052(PART I) /IFB/2014/1723 Dated 14.08.2014

In exercise of the powers conferred by sub-section (3) of section 34 of the Boilers Act, 1923 (5 of 1923) (hereinafter referred to as the “said Act”), the Government of Goa, being satisfied that having regard to the material design or construction of boilers and to the need for rapid industrialization of the country, it is necessary so to do, hereby exempts the boilers and its components whose heating surface area is less than 1,000 square metres, which have been installed or which will be installed in future, from the operation of the provisions of clauses (a) and (b) of section 6, sections 7 to 16, sections 19 to 27 and section 30 of the said Act, subject to the following conditions, namely:-

- (1) before the use of a boiler, the owner of the boiler shall inform alongwith the following documents to the Chief Inspector and will get a receipt of the same -
 - (a) as per the provisions of clause (c) of sub section (1) of section 14 of the said Act, all the necessary documents as provided in regulation 4 of the Indian Boiler Regulations, 1950, alongwith the application for registration of the Boiler;
 - (b) a certificate from the “Competent Person” in the Proforma annexed herein below with regard to the boiler for a period , not exceeding twelve months and the maximum pressure for which it can be safely used;
 - (c) a treasury receipt towards the fees as prescribed in sub-rule (1) of rule 36 of the Goa Boiler Rules, 1983;
- (2) for the boiler in use, the owner of the boiler shall inform alongwith the following documents to the Chief Inspector and will get a receipt of the same –
 - (a) a certificate from the “Competent Person” in the Proforma annexed hereinbelow with regard to the boiler for a further period, not exceeding twelve months and the maximum pressure for which it can be safely used;
 - (b) a treasury receipt towards the fees as prescribed in sub-rule (2) of rule 36 of the Goa Boiler Rules, 1983;

For the purpose of granting a certificate, a “Competent Person” means a person -

- (i) who has a Degree in Mechanical or Production or Power Plant or Metallurgical Engineering from a recognized university and having an experience of atleast five years in maintenance / operation of Boilers;

OR

- (ii) Inspector of Boilers;

- (3) A fresh certificate from the Competent Person shall be submitted to the Chief Inspector for the remaining period if during the period for which the certificate issued by the Competent Person as required under clause (1) or (2) above, any structural alteration, addition or renewal is made to the Boiler or its components.
- (4) If and when the documents as mentioned in clause (1), which are desired by the Chief Inspector or the District Magistrate, under whose jurisdiction the boiler is installed, the owner of the boiler shall produce such documents.
- (5) It will be the responsibility of the owner of the boiler to run and maintain it as per provisions of the said Act and rules framed thereunder. He will also be responsible for any violation of the provisions or accident.
- (6) If the owner of the boiler violates any provision of the said Act or the rules framed thereunder, a penalty of Rs.50,000/- can be imposed on him. If he continues to violate the provision, a penalty of Rs.1,000/- per day can be imposed and / or restriction can be imposed on the use of boiler. The Chief Inspector will be competent to impose the penalty or stop the use of boiler. The owner can file an appeal with the Appellate Authority within 30 days of the order passed by the Chief Inspector, whose order shall be final.

PROFORMA

CERTIFICATE FOR USE OF A BOILER

Registry Number of Boiler	Type of Boiler
Boiler Rating	Place and year of manufacture
Maximum continuous evaporation	
Name of Owner	
Situation of Boiler	
Repairs	
Remarks	
Hydraulically tested on	to lbs. Per sq. inch

I hereby certify that I have personally inspected the above described boiler and its components on in accordance with the procedure for the inspection of boilers prescribed in Chapter IX of the Indian Boiler Regulations, 1950 and Chapter V of The Goa Boiler Rules, 1983 and that the said Boiler is fit for use / further use (strike out whichever is not applicable) at a maximum pressure of lbs. per sq. Inch, for a period from to

The loading of the safety valve is not to exceed

Signature of the Competent Person

Signature of Boiler Owner

Dated : -

Name of the Competent Person (in block letters)

Qualification (Certificates to be enclosed in case other than Inspector of Boilers)

Full Address

Tel. No. / Mobile No.

If employed by a company or association, name
and address of the company or association

**By Order and in the name of
the Governor of Goa**

Sd/-
(S. M. PARANJAPE)
Chief Inspector of Factories & Boilers
and Ex-Officio Joint Secretary

To,

The Director (Printing & Stationary)

Govt. Printing Press, Panajiwith a request to publish the said Notification in
the Official Gazette.